

DATE: 5/10/2021

BY: OM GHARTY CHHETRI, PE, ICIVIL ENGINEERING

| S.N. | AUTHOR | COMMENTS | RESPONSE |
|------|----------|--|--|
| 1. | TDAVIS1 | Provide a detailed traffic control plan for all work within TxDOT ROW. The TCP shall be signed and sealed by a professional engineer licensed in the State of Texas. Show all required signs and devices with proper spacing. Include the Traffic Control Standard Plan sheets TCP (2-1) – XX and TCP (2-X) – XX Standard(s) that match the highway geometrics for the work location closure of one lane, and TCP (1-1) – XX. Example: TCP (2-6)-XX will be needed for proposed work on a one way frontage road. | TCP is provided. All required signs and devices are shown. Standard traffic control plan sheets are included. |
| 2. | TDAVIS1 | Include the Austin Traffic Standard Detail sheet "WORKSHEET FOR EDGE CONDITION TREATMENT TYPES". This Standard Detail sheet can be found in the Austin Traffic Standards with the file name (edgecon.dgn). | Austin Traffic Detail sheet "WORKSHEET FOR EDGE CONDITION TREATMENT TYPES" is included. |
| 3. | TDAVIS1 | Include Fort Worth Standard plan sheet CP-TEP-XX (FW) Concrete Pavement Ties to Existing Pavement) for connections to existing highway concrete pavement, if applicable. | Fort Worth Standard plan sheet CP-TEP (FW) "Concrete Pavement Ties to Existing Pavement" for connections to existing highway concrete pavement is included. |
| 4. | TDAVIS1 | Include all recently updated "Barricade and Construction Standards". BC (XX)-XX (12 sheets) and WZ (TD)- XX. Some sheets may not be needed for known conditions. | No lane closure is proposed during construction. Construction proposed only between curb and TxDOT Right of way. Therefore BC and WZ standards are not applicable. |
| 5. | TDAVIS1 | Include (as needed for any proposed permanent markings) Standard plan sheet PM (X) – XX or FPM (X) – XX, for any proposed permanent striping, markings and words required when said work is being done on the State ROW. | Construction proposed only between curb and TxDOT Right of way. Striping is not proposed |
| 6. | TDAVIS1 | Fill in MPH | MPH is filled. |
| 7. | KBUDIDET | Please show the dimensions for the proposed driveway including throat width and turn radius. | The driveway marked is existing. The throat dimension and turn radius are labeled. |
| 8. | N/A | Use CSWD (FTW)--Concrete Sidewalk Details, Fort Worth standard | Detail added. |